

# Exporte & Reporte



## RCM Report



General	
Customer	Janitza
Contact	Max Mustermann
Inspector	Max Mustermann
Company	Janitza
City	Wetzlar
ZIP	35633
Date	10.11.2016
Software	Janitza-GridVis 7.2
Settings	
Start Date	01.10.2016
End Date	31.10.2016
Network	TN-S
Threshold 1	30 mA
Threshold 2	100 mA
Threshold 3	300 mA
Threshold 4	not configured
Dynamic Threshold	selected

Comments	

Signatory	
Date:	
Signature:	

>= 0

>= 1

>= 2

2

Overview		
Measuring Point	Channel	Test
UMG96RM-E-RCM	L5	Passed
UMG20CM	Eingang 1	Passed
UMG20CM	Eingang 2	Passed
UMG20CM	Eingang 3	Failed
UMG20CM	Eingang 4	Failed

UMG96RM-E-RCM - L5 (Strom effektiv)			
	Value Total	Value %	Result
Max Value	898.24 mA		
Total Values	2976	100.0%	
Violations 30 mA Count	65	2,18 %	Passed
Violations 100 mA Count	30	1,00 %	Passed
Violations 300 mA Count	11	0,37 %	Passed
Violations Dyn. Count	0	0	Passed

UMG20CM - Eingang 1 (Strom effektiv)			
	Value Total	Value %	Result
Max Value	0.0 mA		
Total Values	2976	100.0 %	
Violations 30 mA Count	44	1,48 %	Passed
Violations 100 mA Count		0,17 %	Passed

---

Software: GridVis 7

V 1.0

Themenverwandte Links